

Title: Seismic Assessment of Steel Chemical Storage Tanks.

Authors:

Chun-Wei Chang (Presenter and Contact person)

Assistant Engineer, Technical Division of Taipei Water Department
131, ChangXing Street, Taipei 10672, Taiwan, R.O.C.

Phone: (886)2-8733-5698

Fax: (886)2-8733-5944

E-mail: chunwei@water.gov.taipei

Gee-Yu Liu (co-author)

Associate Researcher, Earthquake Disaster Simulation Division
National Center for Research on Earthquake Engineering (NCREE)
200, Sec.3, Xinhai Rd., Taipei 106, Taiwan

Phone: (886)2-6630-0835

Fax: (886)2-6630-0858

E-Mail: karl@ncree.narl.org.tw

Seismic Assessment of Steel Chemical Storage Tanks.

Chun-Wei Chang¹, Gee-Yu Liu²

¹ Taipei Water Department, Taiwan

² National Center for Research on Earthquake Engineering, Taiwan

ABSTRACT

Water supply is one the crucial lifeline systems. The seismic safety of critical water facilities is a pivotal issue in urban earthquake hazard mitigation. This project conducts the seismic assessment of two typical steel chemical storage tanks (one in Zhitan and one in Changxing water purification plants) of Taipei Water Department. The assessment criteria follow Taiwan Building Seismic Design Code (2011; design response spectra), JWVA Guideline to and Explanation of Seismic Construction Method of Water Supply Facilities (2009; water pipe bridges) and API 650 Welded Steel Tanks for Oil Storage (11th ed., 2012, Appendix E: Seismic Design of Storage Tanks; steel tanks). Major findings include: Tank No. 2 of Zhitan and Tank No. 6 of Changxing do not have sufficient anchorage; also, the later doesn't have enough freeboard while at its highest content level. Accordingly, measures to enhance their seismic integrity or secure their seismic safety have been advised.

Keywords: Water facilities, Seismic assessment, Steel chemical storage tanks, API 650

INTRODUCTION

The steel chemical storage tanks selected for study under this project are No. 2 tank of Zhitan and No. 6 tank of Changxing water purification plant. They are the largest tanks of respective plant with capacity of 300 Tons and the heights are 7.7 meters and 9.2 meters and for accommodating PAC and NaOH respectively. The chemicals (liquid) posed remarkable weight, and any damage of the tanks could result detrimental effects to the purification quality. A rational approach to assess the seismic safety of such tanks is greatly needed..

SEISMIC ASSESSMENT PROCEDURE OF STEEL CHEMICAL STORAGE TANKS

For the design of these hazardous liquid storage tanks, “Appendix E: Seismic Design of Storage Tanks” in API 650 Welded Steel Tanks for Oil Storage (API, 2007) is most applied. Theoretically, it considers two response modes of a tank and its contents: impulsive and convective (Housner, 1963). This procedure applies to anchored steel tanks, which are the most commonly used variety, and is of high seismic concern in Taiwan. It is also incorporated with the ground motion specified in Taiwan Building Seismic Design Code (Construction and Planning Agency Ministry of the Interior, R.O.C., 2011).

API 650 classifies tanks into three Seismic User Groups (SUGs). **SUG III** tanks are those that provide service to facilities essential to the life and health of the public, or those that contain hazardous substances, to which it is greatly important to prevent public exposure. **SUG II** tanks are

those that provide direct services to major facilities, or which store materials that may pose a public hazard and lack secondary controls. The rest belong to **SUG I** tanks.

In this study, a seismic assessment procedure for steel liquid storage tanks is given, as depicted in **Fig. 1**.





Fig. 1 Seismic assessment procedure for steel liquid storage tanks following API 650, App. E requirements.

1. Determine T_i (s) and T_c (s), the natural periods of vibration for impulsive and convective (sloshing) modes of behavior of the liquid.

$$T_i = \frac{1}{\sqrt{2000}} \cdot \left(\frac{C_i H}{\sqrt{\frac{t_w}{D}}} \right) \cdot \sqrt{\frac{\rho}{E}} \quad T_c = 2\pi \cdot \sqrt{\frac{D}{3.68g \cdot \tanh\left(\frac{3.68H}{D}\right)}}$$

where the coefficient C_i is a function of H/D depicted in the following chart.



2. Determine A_i (g) and A_c (g), the impulsive and convective design spectral response acceleration coefficients.

$$A_i = \left(\frac{I}{R_{wi}} \right) \cdot S_{aD}(T_i) \quad A_c = K \cdot \left(\frac{I}{R_{wc}} \right) \cdot S_{aD}(T_c)$$

where I is set by Seismic User Group (SUG), and $K = 1.5$ unless otherwise specified. The values of force reduction coefficients R_{wi} and R_{wc} for the impulsive and convective modes using allowable stress design methods are 4 and 2, respectively, for mechanically-anchored tanks.

3. Determine V (N), the total base shear, from W_i (N) and W_c (N), the effective impulsive and convective portions of the liquid weight, respectively. Examine the possibility of tank sliding.

$$V = \sqrt{V_i^2 + V_c^2}$$

where

$$\begin{cases} V_i = A_i(W_s + W_r + W_f + W_i) \\ V_c = A_c W_c \end{cases} \quad W_i = \begin{cases} \frac{\tanh\left(0.866 \frac{D}{H}\right)}{0.866 \frac{D}{H}} \cdot W_p & D/H \geq 1.333 \\ \left(1.0 - 0.218 \frac{D}{H}\right) \cdot W_p & D/H < 1.333 \end{cases} \quad W_c = 0.230 \frac{D}{H} \cdot \tanh\left(\frac{3.67H}{D}\right) \cdot W_p$$

The calculated value of V should not exceed the sliding resistance V_s (N) calculated by:

$$V_s = \mu(W_s + W_r + W_f + W_p)(1.0 - 0.4A_v)$$

4. Determine the ringwall overturning moment M_{rw} (N-m) acting at the base of tank shell perimeter and the slab overturning moment M_s (N-m) used for slab and pile cap design.

$$M_{rw} = \sqrt{[A_i(W_i X_i + W_s X_s + W_r X_r)]^2 + [A_c(W_c X_c)]^2}$$

$$M_s = \sqrt{[A_i(W_i X_{is} + W_s X_s + W_r X_r)]^2 + [A_c(W_c X_{cs})]^2}$$

where X_i and $X_{..}$ refer to the height from the bottom of the tank shell to the center of action of various lateral seismic forces from liquid, tank shell and roof.

$$X_i = \begin{cases} 0.375H & D/H \geq 1.333 \\ \left(0.5 - 0.094 \frac{D}{H}\right)H & D/H < 1.333 \end{cases} \quad X_c = \left[1.0 - \frac{\cosh\left(\frac{3.67H}{D}\right) - 1}{\frac{3.67H}{D} \cdot \sinh\left(\frac{3.67H}{D}\right)} \right] H$$

$$X_{is} = \begin{cases} 0.375 \left[1.0 + 1.333 \left(\frac{0.866 \frac{D}{H}}{\tanh\left(0.866 \frac{D}{H}\right)} - 1.0 \right) \right] H & D/H \geq 1.333 \\ \left(0.5 + 0.060 \frac{D}{H}\right)H & D/H < 1.333 \end{cases} \quad X_{cs} = \left[1.0 - \frac{\cosh\left(\frac{3.67H}{D}\right) - 1.937}{\frac{3.67H}{D} \cdot \sinh\left(\frac{3.67H}{D}\right)} \right] H$$

5. Determine σ_T , the total combined hoop stress in the shell (MPa).

$$\sigma_T(\pm) = \frac{N_h \pm \sqrt{N_i^2 + N_c^2 + (A_v N_h)^2}}{t}$$

where the product hydrostatic membrane force N_h (N/mm), and the impulsive and convective hoop membrane forces N_i (N/mm) and N_c (N/mm) in tank shell, respectively, are calculated by:

$$N_h = \frac{9.81 \cdot GDY}{2}$$

$$N_i = \begin{cases} 8.48A_i GDH \left[\frac{Y}{H} - 0.5 \cdot \left(\frac{Y}{H}\right)^2 \right] \cdot \tanh\left(0.866 \frac{D}{H}\right) & D/H \geq 1.333 \\ 5.22A_i GD^2 \left[\frac{Y}{0.75D} - 0.5 \cdot \left(\frac{Y}{0.75D}\right)^2 \right] & D/H < 1.333 \text{ and } Y < 0.75D \\ 2.6A_i GD^2 & D/H < 1.333 \text{ and } Y \geq 0.75D \end{cases}$$

$$N_c = \frac{1.85A_c GD^2 \cdot \cosh\left[\frac{3.68(H-Y)}{D}\right]}{\cosh\left(\frac{3.68H}{D}\right)}$$

6. Examine P_{AB} , the anchor load (N).

$$P_{AB} = \left(\frac{1.273M_{rw}}{D^2} - w_t(1 - 0.4A_v) \right) \cdot \left(\frac{\pi D}{n_A} \right)$$

The calculated value of P_{AB} should not exceed 80% of the yield strength of anchor bolts.

7. Examine σ_c , the maximum longitudinal shell compression stress (MPa).

$$\sigma_c = \left(w_t(1 + 0.4A_v) + \frac{1.273M_{rw}}{D^2} \right) \cdot \frac{1}{1000t_s}$$

The calculated value of σ_c should not exceed the allowable longitudinal shell-membrane compression stress F_c (MPa) calculated by:

$$F_c = \begin{cases} 83 \cdot t_s / D & GHD^2 / t^2 \geq 44 \\ 83 \cdot t_s / (2.5D) + 7.5\sqrt{GH} < F_{ty} & GHD^2 / t^2 < 44 \end{cases}$$

8. Examine that the overturning stability ratio is 2.0 or greater.

$$\frac{0.5D \cdot (W_p + W_f + W_T + W_{fd} + W_g)}{M_s} \geq 2.0$$

9. Determine δ_s , the height (mm) of sloshing wave above the product design height. Examine the sufficiency of tank freeboard to accommodate the calculated value of δ_s .

$$\delta_s = 0.5DA_f$$

where

$$A_f = \begin{cases} KS_{D1}I \cdot \left(\frac{1}{T_c}\right) & T_c \leq 4 \\ KS_{D1}I \cdot \left(\frac{4}{T_c^2}\right) & T_c > 4 \end{cases} \quad A_f = \begin{cases} KS_{D1} \cdot \left(\frac{1}{T_c}\right) & T_c \leq T_L \\ KS_{D1} \cdot \left(\frac{T_L}{T_c^2}\right) & T_c > T_L \end{cases}$$

Nomenclatures	
A_v : vertical earthquake acceleration coefficient (g), taken as $0.14S_{DS}$ or greater for the ASCE 7 method	T_L : regional-dependent transition period for longer period ground motion (s)
D : nominal tank diameter (m)	t : thickness of shell ring under consideration (mm)
E : elastic modulus of tank material (MPa)	t_s : thickness of bottom shell (mm)
F_{ty} : yield strength of shell (MPa)	t_u : equivalent uniform thickness of tank shell (mm)
G : product specific gravity	W_f : weight of the tank bottom (N)
g : acceleration due to gravity (m/sec^2)	W_{fd} : total weight of tank foundation (N)
H : maximum design product level (m)	W_g : weight of soil over tank foundation footing (N)
I : importance factor coefficient; $I = 1.0, 1.25$ and 1.5 for SUG I, II and III, respectively	W_p : total weight of the tank contents (N)
K : coefficient for adjusting spectral acceleration (from 5 to 0.5% damping)	W_r : total weight of fixed tank roof (N)
n_A : number of anchors around the tank circumference	W_s : total weight of tank shell and appurtenances (N)
$S_{ad}(T)$: design earthquake spectral response acceleration coefficient for structural period T	W_T : total weight of tank shell, roof, framing, knuckles, product, bottom, attachments and appurtenances (N)
S_{D1} : design (5% damped) spectral response acceleration parameter at one second	w_r : tank and roof weight acting at base of shell (N/m)
S_{DS} : design (5% damped) spectral response acceleration parameter at short periods (0.2s)	Y : distance from liquid surface to any point (positive down (m))
	μ : friction coefficient for tank sliding (max. 0.4)
	ρ : density of fluid (kg/m^3)

SEISMIC ASSESSMENT OF STEEL CHEMICAL STORAGE TANKS

● Seismic Assessment Database of Tanks

The seismic assessment database of No. 2 Tank in Zhitan and No. 6 Tank in Changxing purification plant are given below as **Table 1**:

Table 1 –Seismic Assessment Database of Tanks

NO. of Tank	Zhitan Purification Plant No. 2 Storage Tank	Changxing Purification Plant No. 6 Storage Tank
Address.	No. 2, Zhitan Road, Xindian Dist. New Taipei City	No. 131, Changxing Street, Daan Dist. Taipei City
Coordinates	N <u>24.941647</u> E <u>11.529174</u>	N <u>25.014429</u> E <u>121.549655</u>
Type of Chemical	NaOH solution, concentration 45%, Sp. G: 1.48	Poly Aluminum Chloride solution, Sp. G 1.15
Shape and dimensions of tank body	<input checked="" type="checkbox"/> Cylinder <input type="checkbox"/> Rectangular OD : <u>7.6</u> m Height : <u>7.665</u> m Effluent height : <u>6.735</u> m(from bottom up) Shell thickness : <u>6</u> mm Bottom plate thicknes : <u>6</u> mm Capacity : <u>300</u> MT	<input checked="" type="checkbox"/> Cylinder <input type="checkbox"/> Rectangular OD : <u>6.8</u> m Height : <u>9.16</u> m Effluent height : <u>8.66</u> m Effluent height: <u>8.66</u> M(from bottom up) Shell thickness : <u>4.5-6</u> mm Bottom plate thicknes : <u>6</u> mm Capacity : <u>300</u> MT
Building material of tank	<input checked="" type="checkbox"/> Steel <input checked="" type="checkbox"/> W/inner lining : <u>yes (FRP)</u>	<input checked="" type="checkbox"/> Steel <input checked="" type="checkbox"/> W/ Inner Lining : <u>yes (FRP)</u>
Placing Manner	<input checked="" type="checkbox"/> Elevated Height of bottom plate : <u>2.80</u> m RC Base : <u>yes</u> Foundation pile: <u>nil</u> Anchored with bolts : <u>yes</u> Numbers of Anchoring Bolt: <u>18</u> Spec. of bolt: <u>M20</u>	<input checked="" type="checkbox"/> Ground RC Base : <u>yes</u> Foundation pile: <u>yes</u> Anchored with bolts : <u>yes</u> Numbers of Anchoring Bolt: : <u>16</u> Spec. of bolt: <u>M25</u>
Location placed	<input checked="" type="checkbox"/> Outdoor <input checked="" type="checkbox"/> W/O effluent pond/ channel	<input checked="" type="checkbox"/> Outdoor <input checked="" type="checkbox"/> W/O effluent pond
Year completed	<u>2013</u> <input checked="" type="checkbox"/> No seismic resistance reinforcement	<u>2007</u> <input checked="" type="checkbox"/> No seismic resistance reinforcement

<p>Seismic Assessment Database</p>	<p> $S_S^D = 0.6$ 、 $S_1^D = 0.35$ ； $N_a^{(D)} = 1.0$ 、 $N_v^{(D)} = 1.0$ ； Type 2 Crust , $F_a^{(D)} = 1.1$ 、 $F_v^{(D)} = 1.4$ ； $S_{DS} = 0.66$ 、 $S_{D1} = 0.49$ ； $A_v = 0.14S_{DS} = 0.0924$ ； $T_0^D = S_{D1} / S_{DS} = 0.74$ ； Steel elasticity modal $E = 207,000$ MPa ； $g = 9.81\text{m/s}^2$ ； $H / D = 0.887$, $C_i = 6.1$ ； $T_i = 0.0874\text{s}$ 、 $T_c = 2.887\text{s}$ (procedure 1) ； $I = 1.5$ ； $K=1.5$ $R_{wi}=4$(mechanically-anchored) $R_{wc}=2$(mechanically-anchored) $A_i=0.187$ 、 $A_c=0.297$(procedure 2)； $\rho_s=7850\text{Kg/m}^3$ $W_s=8.46 \times 10^4\text{N}$ ； $W_i=2.24 \times 10^4\text{N}$ $W_f=2.1 \times 10^4\text{N}$ ； $W_p=4.43 \times 10^6\text{N}$ $W_i=3.34 \times 10^6\text{N}$ ； $W_c=6.48 \times 10^5\text{N}$ (procedure 3) ； $M_{rw}=2.62 \times 10^6\text{N-m}$；$M_s=3.01 \times 10^6\text{N-m}$ (procedure 4) ； </p>	<p> $S_{DS} = 0.6$ 、 $S_{D1} = S_{DS} \cdot T_0^D = 0.78$ ； $A_v = 0.14S_{DS} = 0.084$ ； $T_0^D = 1.30\text{s}$ ； $S_{aD} = 0.6$ ； Steel elasticity modal $E = 207,000$ MPa ； $g = 9.81\text{m/s}^2$ ； $H / D = 1.27$, $C_i = 6.6$ ； $T_i = 0.117\text{s}$ 、 $T_c = 2.727\text{s}$ ； (procedure 1) ； $I = 1.5$ ； $K=1.5$ $R_{wi}=4$(mechanically-anchored) $R_{wc}=2$(mechanically-anchored) $A_i=0.225$ 、 $A_c=0.675$(procedure 2)； $\rho_s=7850\text{Kg/m}^3$ $W_s=7.91 \times 10^4\text{N}$ ； $W_i=1.35 \times 10^4\text{N}$ $W_f=1.68 \times 10^4\text{N}$ ； $W_p=3.59 \times 10^6\text{N}$ $W_i=2.98 \times 10^6\text{N}$ ； $W_c=6.48 \times 10^5\text{N}$ (procedure 3) ； $M_{rw}=3.95 \times 10^6\text{N-m}$；$M_s=4.46 \times 10^6\text{N-m}$ (procedure 4) ； </p>
<p>Photo</p>		

● Results of Detail Seismic Resistance Assessment

Concluding the above database and analysis, the of No. 2 Tank in Zhitan and No. 6 Tank in Changxing purification plant seismic assessment results are shown in **Table 2** and **Table 3**.

Table 2 –Results of Detail Seismic Resistance Assessment- No. 2 Tank in Zhitan Purification Plant

Item	Results of Detail Seismic Resistance Assessment
The possibility of tank sliding	The total base shear for tank sliding $V=7.34 \times 10^5 \text{N}$ The sliding resistance $V_S=1.76 \times 10^6 \text{N}$ $V_S > V$OK. (procedure 3)
The total combined hoop stress in the shell	$\sigma_{T(+)}=70.84 \text{MPa}$ (tension,at the bottom of the tank) $\sigma_{T(-)}=-7.807 \text{MPa}$ (compression,at the liquid surface) SUS304 stainless steel $f_y=206 \text{Mpa} > \sigma_{T(+)}$ or $\sigma_{T(-)}$OK. (procedure 5)
The anchor load	$w_t=4.48 \times 10^3 \text{N/m}$ $P_{AB}=7.09 \times 10^4 \text{N}$ 80% of the yield strength of anchor bolts= $80\% \times 6.47 \times 10^4 \text{N}=5.18 \times 10^4 \text{N} < P_{AB}$NG (procedure 6) Anchor bolts do not have sufficient anchorage
The maximum longitudinal shell compression stress	The maximum longitudinal shell compression stress $\sigma_c=10.4 \text{Mpa}$ The allowable longitudinal shell-membrane compression stress $F_C=49.87 \text{Mpa}$ $F_C > \sigma_c$OK. (procedure 7)
The stability against overturning	The overturning stability ratio is $5.75 > 2.0$OK. (procedure 8) .
The height of sloshing wave	The height of sloshing wave $\delta_s=0.97 \text{m}$ The tank freeboard= $7.665-6.735=0.93 \text{m} \approx \delta_s$OK. (procedure 9) . The height of sloshing wave δ_s is slightly higher than the tank freeboard, but is determined as acceptable.

Table 3 –Results of Detail Seismic Resistance Assessment- No. 6 Tank in Changxing Purification Plant

Item	Results of Detail Seismic Resistance Assessment
The possibility of tank sliding	The total base shear for tank sliding $V=8.21 \times 10^5 \text{N}$ The sliding resistance $V_S=1.43 \times 10^6 \text{N}$ $V_S > V$OK. (procedure 3)
The total combined hoop stress in the shell	$\sigma_{T(+)}=62.33 \text{MPa}$ (tension,at the bottom of the tank) $\sigma_{T(-)}=-14.72 \text{MPa}$ (compression,at the liquid surface) SUS304 stainless steel $f_y=206 \text{Mpa} > \sigma_{T(+)}$ or $\sigma_{T(-)}$OK. (procedure 5)

The anchor load	$w_t=4.33 \times 10^3 \text{N/m}$ $P_{AB}=1.4 \times 10^5 \text{N}$ 80% of the yield strength of anchor bolts= $80\% \times 1.01 \times 10^5 \text{N}=0.81 \times 10^5 \text{N} < P_{AB}$NG(procedure 6) Anchor bolts do not have sufficient anchorage
The maximum longitudinal shell compression stress	The maximum longitudinal shell compression stress $\sigma_c=18.87 \text{ Mpa}$ The allowable longitudinal shell-membrane compression stress $F_c=52.96 \text{ Mpa}$ $F_c > \sigma_c$OK. (procedure 7)
The stability against overturning	The overturning stability ratio is $3.64 > 2.0$OK. (procedure 8).
The height of sloshing wave	The height of sloshing wave $\delta_s=1.46 \text{m}$ The tank freeboard= $9.16-8.66=0.5 \text{m} < \delta_s$NG. (procedure 9). The height of sloshing wave δ_s is higher than the tank freeboard.

CONCLUSION AND SUGGESTION

Basis “API650 ,Appendix E(API, 2007) “ and the basic data as well as site survey of the two steel chemical storage tanks in water treatment, the resistance against anchor load of Zhitan No. 2 Tank and Changxing No. 6 Tank is shown as insufficient. Under design seismic conditions, damage to anchoring position may be resulted. Taipei Water Department has established plan to reinforce anchoring bolts, either to increase or to replace so that the anchoring force will be meeting the need of design seismic resistance. Besides, the height of sloshing wave is higher than the freeboard of Changxing No. 6 Tank about 1 meter. This may lead damage to the top plate due to sloshing wave of fluid during earthquake. New requirement has been set that the liquid level operation height must be 1 meter or more lower than the sufficiency of tank freeboard.

The existing large capacity steel chemical storage tanks similar to Zhitan No. 2 Tank or Changxing No. 6 Tank ,may be existed with insufficient anchoring capacity and insufficient freeboard. This is probably a systematic issue and shall be inspected totally to avoid occurrence of any unnecessary damage.

REFERENCES

- [1]API (American Petroleum Institute), 2007, “API 650 Welded Steel Tanks for Oil Storage,” 11-th Ed.
- [2]Housner, G.W. 1963, “Dynamic Analysis of Fluids in Containers Subjected to Acceleration,” Nuclear Reactors and Earthquakes, Appendix F, Report No. TID 7024, U.S. Atomic Energy Commission, Washington D.C.
- [3]Gee-Yu Liu .2015,” Assessment of Steel Liquid Storage Tanks” , National Center for Research on Earthquake Engineering (NCREE), Taiwan
- [4]Construction and Planning Agency Ministry of the Interior,R.O.C. , 2011 , ” Taiwan Building Seismic Design Code” , Taipei.
- [5]Taipei Water Department , 2014 , ” Seismic Assessment of Water Pipe Bridges,Chemical Storage Tanks,and Distribution reservoirs” , Taipei.